





VALVE BOX AND COVER CAST IRON 2 PIECE SCREW TYPE



2" S/S SCH 80 COUPLING
2"x1" S/T REDUCING BUSHING
1" ALL THREADED SCH 80 NIPPLE
METER STOP FORD #B13-444W

P.L.



D1200 METER BOX
W/BLUE LID


6" PVC PIPE OVER WATER VALVE
(PVC PIPE IS TO MOVE FREELY
INSIDE VALVE COVER ASSEMBLY,
PVC PIPE IS TO EXTEND 1" INTO BOTTOM
OF THE BELL ON THE IRON RISER.

P.L.

1'

NOTE:

TEE OR SADDLE - 2" CORPORATION STOP - FORD P/N FB500-7,
2"x4" BRASS NIPPLE, 2" BALL VALVE-FORD P/N B11-777W, 2" X
4" BRASS NIPPLE, 2" SCH 80 S/T COUPLING



TEE OR FORD OR CLOW VEGA POWER
SEAL DOUBLE IRON STRAP STYLE TAPPING
SADDLE, SIDE TAP


WATER MAIN

VALVE BOX

2" SCH 40 PVC WATER LINE
SLEEVED IN 4" PVC ON ROAD
CROSSINGS ONLY


NOTE:

1. ALL SERVICES 20' AND LONGER SHALL BE CONSIDERED LONG SERVICES. SHORTER THAN 20' SHALL BE CONSIDERED SHORT SERVICES.
2. ALL MATERIAL USED SHALL MEET CITY OF HORSESHOE BAY STANDARDS.



City of
Horseshoe Bay

SINGLE WATER SERVICE
DETAIL
NOT TO SCALE



*Willis Environmental
Engineering, Inc.*
CONSULTING ENGINEERS
TX REGISTRATION NO. F-2782
310 MAIN STREET, MARBLE FALLS, TEXAS 78654
• (830) 693-3566 • FAX (830) 693-5362 • e-mail: tplumlee@willis-engineering.com