



# CITY OF HORSESHOE BAY

## IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

The City of Horseshoe Bay has violated monitoring and reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Chapter 30, Section 290, Subchapter F. Even though these were not emergencies, as our customers, you have the right to know what happened and what we are doing (or did) to correct these situations.

*We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During July through December 2017 we did not complete all monitoring and testing for Lead and Copper, and therefore cannot be sure of the quality of your drinking water during that time.*

The table below lists the contaminant(s) we did not properly test for during 2017.

Contaminant	Required sampling frequency	Number of samples taken	When samples should have been taken	When samples were or will be taken
<i>Lead and copper tap water sampling</i>	<i>40 samples</i>	<i>20</i>	<i>Prior to 12/31/2017</i>	<i>1/09/2018</i>

In 2017, TCEQ temporarily changed the City of Horseshoe Bay's Lead and Copper Monitoring program frequency from 20 samples every 3 years, to 40 samples every 6 months in response to our West Water Treatment Plant's upgrade and expansion project completed September of 2017. This resulted in less sampling taken than the new rule required. A thorough reexamination has been conducted of Standard Operating Procedures to improve the internal flow of information regarding State Compliance for updated testing requirements.

The 20 samples taken all tested below regulatory action levels. In 2018 all required samples taken were below regulatory action levels. In the past the City's Lead and Copper samples results have always tested below the regulatory action levels.

If you have any question about this notice or any other City water quality matter, please contact Joshua Hisey, Plant Operations Supervisor at (830) 598-9983 or [jhisey@horseshoe-bay-tx.gov](mailto:jhisey@horseshoe-bay-tx.gov).

Public Water System Number: TX1500015  
Date Distributed: August 2, 2019